

Ambuja Cements Ltd.


IS 269: 2015



CM/L-7029261

(UNIT : PANVEL)

Moha Village, Tal. Panvel, Dist. Raigad - 410206



TEST CERTIFICATE

Date: 14/08/2021

For

53 Grade ordinary Portland Cement Test & Compliance

Sr.No.	Characteristic	Requirement as per IS 269 : 2015	Test Result
CHEMICAL REQUIREMENTS			
1	Total - Loss on Ignition (%)	4.0 (Max.)	2.68
2	Insoluble Residue (% by Mass)	5.0 (Max.)	1.38
PHYSICAL REQUIREMENTS			
1	Fineness		
	Specific Surface m ² / Kg.	225 (Min.)	332
2	Setting Time (Minutes)		
	(a) Initial	30 (Min.)	115
	(b) Final	600 (Max.)	185
3	Soundness		
	Expansion by		
	(a) Le-chatelier Method (mm)	10 (Max.)	1.00
	(b) Auto Clave (%)	0.8 (Max.)	0.05
4	Compressive Strength in Mpa		
	(a) 72 ± 1h (3 days)	27 (Min.)	42.8
	(b) 168 ± 2h (7 days)	37 (Min.)	51.5
	(c) 672 ± 4h (28 days)	53 (Min.)	Under Test
5	Performance Improver		
	Limestone (% by mass)	5.0 (Max.)	---

The Above cement complies with the requirements of IS : 269 - 2015 for 53 Grade Ordinary Portland Cement.

Week No. : 31 / 2021

Authorised Signatory

Corporate office and Mumbai office : Elegant Business park, Near Kohinoor Continental Hotel, Behind Kotak Mahindra Bank, Opp. J. B. Nagar, Off Andheri- Kurla Road, Andheri (East), Mumbai - 400059, Tel. No.:(022)66167000 /40667000,Fax No.:(022) 40667714 / 40667713

Ambuja Cement