

Binani

BRAJ BINANI GROUP

BINANI CEMENT LIMITED

(AN ISO 9001, 14001 & OHSAS 18001 CERTIFIED CO.)

BINANIGRAM, PINDWARA

R/15-22

TEST CERTIFICATE**Ordinary Portland Cement
"53 GRADE"**

IS : 12269



CM/L-8214059

PARTICULARS	TEST RESULTS	REQUIREMENTS AS PER IS-12269-2013
-------------	--------------	-----------------------------------

Chemical Requirements :

1. Lime Saturation Factor $\text{CaO}-0.7\text{SO}_3$ ($2.8\text{SiO}_2+1.2\text{Al}_2\text{O}_3+0.65\text{Fe}_2\text{O}_3$)	0.87	0.8 to 1.02
2. Ratio of % of Alumina to that of Iron Oxide (% Al_2O_3 /% Fe_2O_3)	1.68	0.66 min
3. Insoluble Residue (% by Mass)	2.64	4.00 max
4. Magnesia (% by Mass)	2.32	6.00 max
5. Sulphuric Anhydride (% by Mass)	1.99	3.50 max
6. Total Loss on Ignition(%)	2.84	4.00 max
7. Total Chlorides (%)	0.014	0.10 max

Physical Requirements

1. Consistency (%)	30.25	
2. Fineness (m ² / Kg)	316	225 min.
3. Setting Time (Minutes)		
(a) Initial	120	30 min
(b) Final	170	600 max.
4. Soundness		
(a) Le.Chatelier (mm)	1.0	10.0 max
(b) Autoclave (%)	0.12	0.8 max
5. Compressive Strength (MPa)		
(a) 72 ± 1 h (3 days)	39	27 min
(b) 168 ± 2 h (7 days)	51	37 min
(c) 672 ± 4 h (28 days)	61	53 min

ABOVE CEMENT COMPLIES WITH THE REQUIREMENTS OF IS.12269 : 2013 FOR ORDINARY PORTLAND CEMENT "53 GRADE"

DATE OF DESPATCH 20/02/2016

WEEK NO. 8

CHECKED BY :

BINANI CEMENT LIMITED
Authorised Signatory
53