




THE INDIA CEMENTS LIMITED

WORKS : MALKAPUR - 501158, P.B. No. 07, SY. No. 51,
TANDUR MANDAL, RANGA REDDY DIST., TELANGANA
Tel : 08411 - 242247, 242324 to 242326, Fax : 08411 - 242302



AN IS/ISO 9001:2015 CERTIFIED COMPANY

COROMANDEL KING SUPERIOR OPC 53 GRADE CEMENT TEST CERTIFICATE

<u>PARTICULARS</u>	<u>TEST RESULTS</u>	 Specification as per IS 269:2015
A CHEMICAL REQUIREMENTS:		
1 LSF (Lime Saturation factor)	0.91	0.80-1.02
2 Alumina Modulus	1.21	Min 0.66
3 Insoluble residue (%)	2.49	Max 5.0
4 Magnesia (%)	1.11	Max 6.0
5 Sulphuric Anhydride (%)	2.52	Max.3.5
6 Loss on Ignition (%)	2.53	Max.4.0
7 Chloride (%)	0.015	Max 0.10
B PHYSICAL REQUIREMENTS:		
1 Specific Surface Area (M ² /kg)	306	Min. 225
2 Soundness		
a) Le Chatelier (mm)	2.0	Max 10
b) Autoclave (%)	0.06	Max 0.8
3 Setting Time (minutes)		
a) Initial	145	Min 30
b) Final	220	Max 600
4 Compressive Strength(Mpa)		
a) 3 Days	35.0	Min 27
b) 7 Days	45.0	Min 37
c) 28 Days	53.5	Min 53

The sample complies with the requirements of IS 269:2015 for 53 Grade Ordinary Portland Cement.

Date of Despatch: 19.02.2021 to 25.02.2021 Week No: 08




HOD (QA)

Registered Office : "DHUN BUILDING", 827, Anna Salai, CHENNAI - 600 002.

Corporate Office : Coromandel Towers, 93, Santhome High Road, Karpagam Avenue, R.A. Puram, CHENNAI - 600 028

Phones : (044) 28521526 / 28521527 Fax : (044) 28528106, www.indiacements.co.in

E.CC.No. AAAC1728PXM010, SERVICE TAX No. AAAC1728PST017, PAN No. AAAC1728P

TIN No. 36220189434, TAN No. HYDT03638F

Railway Siding Code : MICT 09528512, Corporate Identity No. (CIN) : L26942TN1946PLC000931