



## JSW OPC Cement : 53 GRADE

**START STRONG.GROW STRONGER.**

### TEST CERTIFICATE

Ordinary Portland Cement as per IS 269:2015

REF.: JSW/QA/2020 27

DATE : 15-07-2020

WEEK NO. : 27

01-07-2020 07-07-2020


CHARACTERISTIC	RESULTS OBTAINED	REQUIREMENT OF IS 269:2015
<b>(A) CHEMICAL COMPOSITION</b>		
(i) Lime Saturation Factor	0.87	0.80 to 1.02
(ii) Alumina Modulus, % by mass	1.94	0.66 Minimum
(iii) Insoluble residue (IR) % by mass	0.37	5.0 Maximum
(iv) Magnesia (MgO) % by mass	2.80	6.0 Maximum
(v) Sulphuric Anhydrite % by mass	2.59	3.5 Maximum
(vi) Loss on ignition (LOI), % by mass	2.93	4.0 Maximum
(vii) Chloride , % by mass	0.018	0.10 Maximum
<b>(B) PHYSICAL TESTING</b>		
<b>1. Fineness of Cement</b>		
Sp.Surface blaine (m <sup>2</sup> /kg)	329	225 minimum
<b>2. Soundness</b>		
Le-Chatelier Expansion (mm)	1.00	10 Maximum
Autoclave Expansion (%)	0.060	0.8 Maximum
<b>3. Setting Time</b>		
Initial (in Minutes)	140	30 Minimum
Final (in Minutes)	180	600 Maximum
<b>4. Compressive Strength (MPa)</b>		
(a) At 72 ± 1 Hrs.	37.77	27 MPa Minimum
(b) At 168 ± 2 Hrs.	46.41	37 MPa Minimum
(c) At 672 ± 4 Hrs.	Result Awaited	53 MPa Minimum

**Remarks :**

1. Temperature during testing - 27 ± 2° c.
2. Ordinary Portland Cement conforms to the requirements of IS 269-2015 in all respects.

**Address:**

JSW CEMENT LIMITED  
 Village- Khar Karavi, Post Office- Gadab  
 Taluka- Pen, District- Raigad  
 402107, Maharashtra. +91 2143 277601/2



Associated General Manager