



## JSW PSC Cement

**START STRONG.GROW STRONGER.**

### TEST CERTIFICATE

Portland Slag Cement as per IS 455:2015

REF.: JSW/QA/2020 27

DATE : 15-07-2020

WEEK NO. : 27

01-07-2020 07-07-2020


CHARACTERISTIC	RESULTS OBTAINED	REQUIREMENT OF IS 455:2015
<b>(A) CHEMICAL COMPOSITION</b>		
(i) Magnesia (MgO), % by mass	4.83	10.0 Maximum
(ii) Insoluble Residue, % by mass	0.39	4.0 Maximum
(iii) Sulphuric Anhydride (SO <sub>3</sub> ) % by mass	2.55	3.5 Maximum
(iv) Sulphide Sulphur (S)	0.29	1.5 Maximum
(v) Loss on Ignition % by mass	1.46	5.0 Maximum
(vi) Total Chloride (Cl), % by mass	0.018	0.10 Maximum
<b>(B) PHYSICAL TESTING</b>		
<b>1. Fineness of Cement</b>		
Sp.Surface blaine (m <sup>2</sup> /kg)	368	225 m <sup>2</sup> /kg minimum
<b>2. Soundness</b>		
Le-Chatelier Expansion (mm)	1.00	10 mm Maximum
Autoclave Expansion (%)	0.057	0.8 % Maximum
<b>3. Setting Time</b>		
Initial (in Minutes)	180	Not less than 30 minutes
Final (in Minutes)	225	Not more than 600 minutes
<b>4. Compressive Strength (MPa)</b>		
(a) At 72 ± 1 Hrs.	32.77	16 MPa Minimum
(b) At 168 ± 2 Hrs.	41.71	22 MPa Minimum
(c) At 672 ± 4 Hrs.	Result Awaited	33 MPa Minimum

**Remarks :**

1. Temperature during testing - 27 ± 2° c.
2. Portland Slag Cement conforms to the requirement of IS 455-2015 in all respects.
3. **Specific Gravity - 3.00 GGBS addition % 52 ± 2**

**Address:**

JSW CEMENT LIMITED  
 Village- Khar Karavi, Post Office- Gadab  
 Taluka- Pen, District- Raigad  
 402107, Maharashtra. +91 2143 277601/2



Associated General Manager