

SANGHI INDUSTRIES LIMITED QUALITY CONTROL LABORATORY

Sanghipuram - 370 511.

Turning Dreams into Concrete Reality Tal.: Abdasa, Dist.: Kutch, State: Gujarat

CM/L 7431062 (NABL ACCREDITED LABORATORY)

Phone (02831) 274131, 274132, 274135, Fax : (02831) 274106,274115, e-mail : info@sanghicement.com

Page No. : 1/1

Certificate No. : CMD/OPC/15.01.2021

Lot Create Date : 16.01.2021

Material : CMOPC53

Lab Code : 15/CM/01-2021

Sample Received From : Packing Plant

Address : SIL-Sanghipuram

Reference : Day Average Com.Despatch During of testing Period : 16.01.2021 To 13.02.2021

Tested as per : IS4031& IS4032 Date of Sample : 15.01.2021

Month : 01

Month : 01 Week : 03

NABL/TP/F30

Issue No.1, Amnd.No.: 03, Eff. Dt.: 19.08.2019

SANGHI CEMENT * SANGHI CEMENT

TEST CERTIFICATE		
PARAMETERS TESTED	REQUIREMENTS AS PER IS 269:2015	RESULTS OBTAINED
1.Chemical Testing		
Loss on Ignition	LESS THAN 4.00%	1.98
Insoluble Residue	LESS THAN 5.00%	2.24
SO3	LESS THAN 3.50%	2.95
SiO2		22.38
Al203		5.30
Fe2O3		4.25
CaO		60.12
MgO	LESS THAN 6.00%	2.14
Chlolride	LESS THAN 0.10%	0.026
LSF	0.80% To 1.02%	0.81
AM	MORE THAN 0.66%	1.25
СЗА	-	6.86
2.Mechanical Testing		
Specific Surface	MORE THAN 225.00m2/kg	299
Normal Consistency		28.3
Setting Time - Initial	MORE THAN 30.00min	125
Setting Time - Final	LESS THAN 600.00min	170
Soundness Lechatelier	LESS THAN 10.00MM	1.5
Soundness Autoclave	LESS THAN 0.80%	0.60
Comp. Strength - 24 Hrs. *		24.6

Conditions:

- 1. The test results pertain to the sample received only.
- 2. This report is being issued with a specific understanding that SIL QC LAB will not in any way be involved in action following the interpretation of above results.
- 3. This report shall not be re-produced except in full without written approval from SIL QC LAB.
- * 1 Day testing is out of NABL scope.

Authorised Signatory

A N G

Н

C

M E

N T

S

N G H

C E M E





SANGHI INDUSTRIES LIMITED QUALITY CONTROL LABORATORY

Sanghipuram - 370 511.

Turning Dreams into Concrete Reality Tal.: Abdasa, Dist.: Kutch, State: Gujarat

(NABL ACCREDITED LABORATORY) CM/L 7431062

Phone (02831) 274131, 274132, 274135, Fax: (02831) 274106,274115, e-mail: info@sanghicement.com

1/1 Page No.

: CMD/OPC/15.01.2021 Certificate No.

Lot Create Date : 16.01.2021 Material : CMOPC53 : 15/CM/01-2021 Lab Code : Packing Plant Sample Received From : SIL-Sanghipuram **Address**

: Day Average Com.Despatch Reference During of testing Period : 16.01.2021 To 13.02.2021

Tested as per : IS4031& IS4032 **Date of Sample** : 15.01.2021

Month : 01 : 03 Week

NABL/TP/F30

Issue No.1, Amnd.No.: 03, Eff. Dt.: 19.08.2019

A N G H E M E N T S A N G H CEMENT

S

C

Comp. Strength - 72 ± 1 Hrs.	MORE THAN 27.00MPa	36.4
Comp. Strength - 168 ± 2 Hrs.	MORE THAN 37.00MPa	46.00
Comp. Strength - 672 ± 4 Hrs.	MORE THAN 53.00MPa	59.30

Conditions:

- 1. The test results pertain to the sample received only.
- 2. This report is being issued with a specific understanding that SIL QC LAB will not in any way be involved in action following the interpretation of above results.
- 3. This report shall not be re-produced except in full without written approval from SIL QC LAB.
- 1 Day testing is out of NABL scope.

Authorised Signatory

Quality Manager

A N G

Н

C

Ε

N T

S

N G

CEME