

TL-1123

An ISO / IEC 17025:2017 Accredited Testing Laboratory

Test Report

Block Jointing Mortar Physical Test

Customer Name	: Recons Building Products Private Limited	Testing Location	: MUMBAI LAB
Office Address	: 8TH FLOOR, 805, 349 BUSINESS POINT, WESTERN EXPRESS HIGHWAY, ANDHERI, Mumbai Suburban, Maharashtra, 400059	Material Code	: OT
		Sample Ref No.	: 35557
Site Name (*)	: Ashar Group	Report No.	: OT-6869/1-1
Description (*)	: Recons Block Jointing Mortar Batch No-HT 26, MFG-26/05/2025	Bill No	: 202526MUM796
Supplier Name	: Recons Building Products Private Limited	Date of Mat. Recd	: 16-Jun-2025
Contact Details	: Mr. Kautilya Bhatt - 9223589024 (Route : R3)	Date of Testing	: 15-Jul-2025
		Date of Issue	: 17-Jul-2025

OBSERVATIONS & CALCULATIONS :

Sr no.	Name of Test	Unit	Test Result
1	Water Demand	%	21.0
2	Pot Life	Minutes	230
3	Loose Bulk Density	kg/l	1.547
4	Compressive Strength (28 days)	N/mm ²	7.54

References :

- 1) BS EN 1015 Methods of test for mortar for masonry (a multi part standard)

Notes :

- 1) (*) indicates- Information has been provided by client.
- 2) Sampling has been carried out by client. DESPL is not responsible for sampling criteria.
- 3) Simple acceptance decision rule is applied as per ILAC G8 for the above conducted test.
- 4) The test reports and results relate to the particular specimen/sample(s) of the material as delivered/received and tested in the laboratory.
- 5) Any test report shall not be reproduced except in full, without the written permission from Durocrete.

This report can be authenticated on our website www.durocrete.in

Authorized Signatory



Neeta Nivangune

(Sr. Manager – Lab Operations)

Checked by : Sarwar Al

--End of Report--

Durocrete Engineering Services Pvt. Ltd.

Mob No. : +91 9850500013 Email : durocrete.mumbai@acts-int.com Website : www.durocrete.in

Lab address: Plot No. A-387, Rd No. 28, MIDC, Wagle Estate, Thane(W)-400604*

Regd. address: Sr.No. 38/23, Near PARI Chowk, Opp. Venkatesh Sharvil, Narhe Ind. Estate, Pune - 411041 CIN: U28939PN1999PTC014212