



# THE INDIA CEMENTS LIMITED

WORKS : MALKAPUR - 501158, P.B. No. 07, SY. No. 51,  
TANDUR MANDAL, RANGA REDDY DIST., TELANGANA  
Tel : 08411 - 242247, 242324 to 242326, Fax : 08411 - 242302



AN IS/ISO 9001:2015 CERTIFIED COMPANY

## COROMANDEL KING SUPERIOR OPC 53 GRADE CEMENT TEST CERTIFICATE

### PARTICULARS

### TEST RESULTS



Specification as per  
IS 269:2015

#### A CHEMICAL REQUIREMENTS:

1	LSF (Lime Saturation factor)	0.90	0.80-1.02
2	Alumina Modulus	1.04	Min 0.66
3	Insoluble residue (%)	2.49	Max 5.0
4	Magnesia (%)	1.06	Max 6.0
5	Sulphuric Anhydride (%)	2.52	Max.3.5
6	Loss on Ignition (%)	2.63	Max.4.0
7	Chloride (%)	0.013	Max 0.10

#### B PHYSICAL REQUIREMENTS:

1	Specific Surface Area (M <sup>2</sup> /kg)	318	Min. 225
2	Soundness		
	a) Le Chatelier (mm)	1.0	Max 10
	b) Autoclave (%)	0.02	Max 0.8
3	Setting Time (minutes)		
	a) Initial	120	Min 30
	b) Final	210	Max 600
4	Compressive Strength(Mpa)		
	a) 3 Days	37.2	Min 27
	b) 7 Days	48.9	Min 37
	c) 28 Days	59.8	Min 53
5	NC(%)	26.0	--
6	Sp.Gravity (gm/CC)	3.13	--

The sample complies with the requirements of IS 269:2015 for 53 Grade Ordinary Portland Cement.

Date of Despatch: 20.08.2022 to 26.08.2022 Week No: 34

Permitted Performance improvers are added (Type: Limestone: 2.0% & Flyash: 3.0%)



HOD (QA)

Registered Office : "DHUN BUILDING", 827, Anna Salai, CHENNAI - 600 002.

Corporate Office : Coromandel Towers, 93, Santhome High Road, Karpagam Avenue, R.A. Puram, CHENNAI - 600 028

Phones : (044) 28521526 / 28521527 Fax : (044) 28528106, www.indiacements.co.in

E.CC.No. AAAC1728PXM010, SERVICE TAX No. AAAC1728PST017, PAN No. AAAC1728P

TIN No. 36220189434, TAN No. HYDT03638F

Railway Siding Code : MICT 09528512, Corporate Identity No. (CIN) : L26942TN1946PLC000931



# THE INDIA CEMENTS LIMITED

WORKS : MALKAPUR - 501158, P.B. No. 07, SY. No. 51,  
TANDUR MANDAL, RANGA REDDY DIST., TELANGANA  
Tel : 08411 - 242247, 242324 to 242326, Fax : 08411 - 242302



AN IS/ISO 9001:2015 CERTIFIED COMPANY

## COROMANDEL OPC 43 GRADE CEMENT TEST CERTIFICATE



Specification as per  
IS 269:2015

### PARTICULARS

### TEST RESULTS

#### A CHEMICAL REQUIREMENTS:

1	LSF (Lime Saturation factor)	0.91	0.66-1.02
2	Alumina Modulus	1.03	Min 0.66
3	Insoluble residue (%)	2.60	Max 5.0
4	Magnesia (%)	1.07	Max 6.0
5	Sulphuric Anhydride (%)	2.32	Max.3.5
6	Loss on Ignition (%)	2.73	Max 5.0
7	Chloride (%)	0.012	Max 0.10

#### B PHYSICAL REQUIREMENTS:

1	Specific Surface Area (M <sup>2</sup> /kg)	296	Min. 225
2	Soundness		
	a) Le Chatelier (mm)	1.0	Max 10
	b) Autoclave (%)	0.03	Max 0.8
3	Setting Time (minutes)		
	a) Initial	123	Min 30
	b) Final	215	Max 600
4	Compressive Strength(Mpa)		
	a) 3 Days	35.0	Min 23
	b) 7 Days	46.2	Min 33
	c) 28 Days	54.8	Min 43 & Max 58
5	NC(%)	26.7	--
6	Sp.Gravity(gm/CC)	3.14	--

The sample complies with the requirements of IS 269:2015 for 43 Grade Ordinary Portland Cement

Date of Despatch: 20.08.2022 to 26.08.2022 Week No: 34

Permitted Performance improvers are added (Type: Limestone: 2.0% & Flyash: 3.0%)



HOD (QA)

Registered Office : "DHUN BUILDING", 827, Anna Salai, CHENNAI - 600 002.

Corporate Office : Coromandel Towers, 93, Santhome High Road, Karpagam Avenue, R.A. Puram, CHENNAI - 600 028

Phones : (044) 28521526 / 28521527 Fax : (044) 28528106, www.indiacements.co.in

E.CC.No. AAAC1728PXM010, SERVICE TAX No. AAAC1728PST017, PAN No. AAAC1728P

TIN No. 36220189434, TAN No. HYDT03638F

Railway Siding Code : MICT 09528512, Corporate Identity No. (CIN) : L26942TN1946PLC000931



# THE INDIA CEMENTS LIMITED

WORKS : MALKAPUR - 501158, P.B. No. 07, SY. No. 51,  
TANDUR MANDAL, RANGA REDDY DIST., TELANGANA  
Tel : 08411 - 242247, 242324 to 242326, Fax : 08411 - 242302



AN IS/ISO 9001:2015 CERTIFIED COMPANY

## COROMANDEL KING SUPER POWER PPC (FA BASED) TEST CERTIFICATE

### PARTICULARS

### TEST RESULTS



Specification as per  
IS:1489(Part-1):2015

#### A CHEMICAL REQUIREMENTS:

1	Sulphuric Anhydride (%)	2.20	Max 3.5
2	Magnesia (%)	1.09	Max 6.0
3	Loss on Ignition (%)	2.41	Max 5.0
4	Insoluble Residue (%)	24.18	Max $X+[4(100-X)/100]$
5	Chloride (%)	0.013	Max. 0.1

#### B PHYSICAL REQUIREMENTS:

1	Specific Surface Area (M <sup>2</sup> /kg)	335	Min. 300
2	Soundness		
	a) Le Chatelier (mm)	1.0	Max 10
	b) Autoclave (%)	0.02	Max 0.8
3	Setting Time (minutes)		
	a) Initial	120	Min 30
	b) Final	210	Max 600
4	Compressive Strength (Mpa)		
	a) 3 Days	28.0	Min. 16
	b) 7 Days	40.0	Min. 22
	c) 28 Days	50.8	Min 33
5	% Drying Shrinkage	Results awaited	Max 0.15
6	% of Flyash	27.0	Min 15 and Max 35
7	NC(%)	27.3	--
8	Sp.Gravity(gm/CC)	2.91	--

The above cement complies to IS: 1489 (Part-1):2015 Portland Pozzolana Cement (Fly ash based).

Date of Despatch: 20.08.2022 to 26.08.2022 Week No: 34



HOD (QA)

Registered Office : "DHUN BUILDING", 827, Anna Salai, CHENNAI - 600 002.

Corporate Office : Coromandel Towers, 93, Santhome High Road, Karpagam Avenue, R.A. Puram, CHENNAI - 600 028

Phones : (044) 28521526 / 28521527 Fax : (044) 28528106, www.indiacements.co.in

E.CC.No. AAAC1728PXM010, SERVICE TAX No. AAAC1728PST017, PAN No. AAAC1728P

TIN No. 36220189434, TAN No. HYDT03638F

Railway Siding Code : MICT 09528512, Corporate Identity No. (CIN) : L26942TN1946PLC000931



# THE INDIA CEMENTS LIMITED

WORKS : MALKAPUR - 501158, P.B. No. 07, SY. No. 51,  
TANDUR MANDAL, RANGA REDDY DIST., TELANGANA  
Tel : 08411 - 242247, 242324 to 242326, Fax : 08411 - 242302



AN IS/ISO 9001:2015 CERTIFIED COMPANY

## COROMANDEL KING SUPERIOR OPC 53 GRADE CEMENT TEST CERTIFICATE

### PARTICULARS

### TEST RESULTS



Specification as per  
IS 269:2015

#### A CHEMICAL REQUIREMENTS:

1	LSF (Lime Saturation factor)	0.90	0.80-1.02
2	Alumina Modulus	1.04	Min 0.66
3	Insoluble residue (%)	2.49	Max 5.0
4	Magnesia (%)	1.06	Max 6.0
5	Sulphuric Anhydride (%)	2.52	Max.3.5
6	Loss on Ignition (%)	2.63	Max.4.0
7	Chloride (%)	0.013	Max 0.10

#### B PHYSICAL REQUIREMENTS:

1	Specific Surface Area (M <sup>2</sup> /kg)	318	Min. 225
2	Soundness		
	a) Le Chatelier (mm)	1.0	Max 10
	b) Autoclave (%)	0.02	Max 0.8
3	Setting Time (minutes)		
	a) Initial	120	Min 30
	b) Final	210	Max 600
4	Compressive Strength(Mpa)		
	a) 3 Days	37.2	Min 27
	b) 7 Days	48.9	Min 37
	c) 28 Days	59.8	Min 53
5	NC(%)	26.0	--
6	Sp.Gravity(gm/CC)	3.13	--

The sample complies with the requirements of IS 269:2015 for 53 Grade Ordinary Portland Cement.

Date of Despatch: 20.08.2022 to 26.08.2022 Week No: 34



HOD(QA)

Registered Office : "DHUN BUILDING", 827, Anna Salai, CHENNAI - 600 002.

Corporate Office : Coromandel Towers, 93, Santhome High Road, Karpagam Avenue, R.A. Puram, CHENNAI - 600 028

Phones : (044) 28521526 / 28521527 Fax : (044) 28528106, www.indiacements.co.in

E.CC.No. AAAC1728PXM010, SERVICE TAX No. AAAC1728PST017, PAN No. AAAC1728P

TIN No. 36220189434, TAN No. HYDT03638F

Railway Siding Code : MICT 09528512, Corporate Identity No. (CIN) : L26942TN1946PLC000931





# THE INDIA CEMENTS LIMITED

WORKS : MALKAPUR - 501158, P.B. No. 07, SY. No. 51,  
TANDUR MANDAL, RANGA REDDY DIST., TELANGANA  
Tel : 08411 - 242247, 242324 to 242326, Fax : 08411 - 242302



AN IS/ISO 9001:2015 CERTIFIED COMPANY

## COROMANDEL KING SUPERIOR OPC 43 GRADE CEMENT TEST CERTIFICATE

### PARTICULARS

### TEST RESULTS



Specification as per  
IS 269:2015

#### A CHEMICAL REQUIREMENTS:

1	LSF (Lime Saturation factor)	0.91	0.66-1.02
2	Alumina Modulus	1.03	Min 0.66
3	Insoluble residue (%)	2.60	Max 5.0
4	Magnesia (%)	1.07	Max 6.0
5	Sulphuric Anhydride (%)	2.32	Max.3.5
6	Loss on Ignition (%)	2.73	Max 5.0
7	Chloride (%)	0.012	Max 0.10

#### B PHYSICAL REQUIREMENTS:

1	Specific Surface Area (M <sup>2</sup> /kg)	296	Min. 225
2	Soundness		
	a) Le Chatelier (mm)	1.0	Max 10
	b) Autoclave (%)	0.03	Max 0.8
3	Setting Time (minutes)		
	a) Initial	123	Min 30
	b) Final	215	Max 600
4	Compressive Strength(Mpa)		
	a) 3 Days	35.0	Min 23
	b) 7 Days	46.2	Min 33
	c) 28 Days	54.8	Min 43 and Max 58
5	NC(%)	26.7	--
6	Sp.Gravity(gm/CC)	3.14	--

The sample complies with the requirements of IS 269:2015 for 43 Grade Ordinary Portland Cement

Date of Despatch: 20.08.2022 to 26.08.2022 Week No: 34



HOD(QA)

Registered Office : "DHUN BUILDING", 827, Anna Salai, CHENNAI - 600 002.

Corporate Office : Coromandel Towers, 93, Santhome High Road, Karpagam Avenue, R.A. Puram, CHENNAI - 600 028

Phones : (044) 28521526 / 28521527 Fax : (044) 28528106, www.indiacements.co.in

E.CC.No. AAAC1728PXM010, SERVICE TAX No. AAAC1728PST017, PAN No. AAAC1728P

TIN No. 36220189434, TAN No. HYDT03638F

Railway Siding Code : MICT 09528512, Corporate Identity No. (CIN) : L26942TN1946PLC000931



# THE INDIA CEMENTS LIMITED


WORKS : MALKAPUR - 501158, P.B. No. 07, SY. No. 51,  
TANDUR MANDAL, RANGA REDDY DIST., TELANGANA  
Tel : 08411 - 242247, 242324 to 242326, Fax : 08411 - 242302



AN IS/ISO 9001:2015 CERTIFIED COMPANY



## CONCRETE SUPER KING PORTLAND POZZALONA CEMENT (FA BASED) TEST CERTIFICATE

<u>PARTICULARS</u>	<u>TEST RESULTS</u>	 <b>Specification as per IS:1489(Part-1):2015</b>
<b>A CHEMICAL REQUIREMENTS:</b>		
1 Sulphuric Anhydride (%)	<b>2.20</b>	Max 3.5
2 Magnesia (%)	<b>1.03</b>	Max 6.0
3 Loss on Ignition (%)	<b>2.63</b>	Max 5.0
4 Insoluble Residue (%)	<b>14.55</b>	Max $X + [4(100-X)/100]$
5 Chloride (%)	<b>0.012</b>	Max. 0.1
<b>B PHYSICAL REQUIREMENTS:</b>		
1 Specific Surface Area (M <sup>2</sup> /kg)	<b>355</b>	Min. 300
2 Soundness		
a) Le Chatelier (mm)	<b>1.0</b>	Max 10
b) Autoclave (%)	<b>0.02</b>	Max 0.8
3 Setting Time (minutes)		
a) Initial	<b>115</b>	Min 30
b) Final	<b>212</b>	Max 600
4 Compressive Strength (Mpa)		
a) 3 Days	<b>35.0</b>	Min. 16
b) 7 Days	<b>44.8</b>	Min. 22
c) 28 Days	<b>56.4</b>	Min 33
5 % Drying Shrinkage	<b>Results awaited</b>	Max 0.15
6 % of Flyash	<b>18.0</b>	Min 15 and Max 35
7 NC(%)	<b>26.7</b>	--

The above cement complies to IS: 1489 (Part-1):2015 Portland Pozzolana Cement (Fly ash based).

Date of Despatch: 20.08.2022 to 26.08.2022 Week No: 34



HOD (QA)

Registered Office : "DHUN BUILDING", 827, Anna Salai, CHENNAI - 600 002.

Corporate Office : Coromandel Towers, 93, Santhome High Road, Karpagam Avenue, R.A. Puram, CHENNAI - 600 028

Phones : (044) 28521526 / 28521527 Fax : (044) 28528106, www.indiacements.co.in

E.CC.No. AAAC1728PXM010, SERVICE TAX No. AAAC1728PST017, PAN No. AAAC1728P

TIN No. 36220189434, TAN No. HYDT03638F

Railway Siding Code : MICT 09528512, Corporate Identity No. (CIN) : L26942TN1946PLC000931